

Inlet Water & Sweep Gas Guidelines for Liqui-Cel® Membrane Contactors

Inlet water and sweep gas quality are important considerations when operating Liqui-Cel® Membrane Contactors. This document provides guidelines for inlet water and sweep gas conditions that may help prevent fouling of the membrane surface or scaling which can negatively impact performance. Design and operating guidelines are also available in the *Liqui-Cel Membrane Contactor Design & Operating Guide* which can be found on the liqui-cel.com web site. This document and the *Design & Operating Guide* should be thoroughly reviewed before designing and operating a system.

When operating a Liqui-Cel Contactor system note the following general recommendations and considerations:

- a comprehensive water quality analysis should be completed. Changes in water quality, such as seasonal variation, should be taken into consideration;
- a softener or cation exchange is recommended if water does not meet quality guidelines;
- liquid and gas inlet streams should always be pre-filtered; and
- the potential for a pH shift should be assessed (for CO₂ removal applications)

The optimal filtration and pre-treatment arrangement will depend on several variables, including the water source, operating conditions, biological matter, organics, total dissolved solids (TDS) and other factors. Additionally, some dissolved compounds could pass through filtration and may deposit on the membrane surface. Particularly, agglomeration or precipitation of certain dissolved compounds could occur with pH changes. To reduce risk of blocking or precipitation a 5 um filter absolute (99.9% efficiency) is recommended.

In addition to filtering to < 5 microns absolute, seawater may require other preventative actions to help reduce the risk of scaling. The following tables provide minimum guidelines that may help prevent membrane fouling and blockage.

Table 1: Inlet Water Quality Guidelines

Water Quality Indicator	Measure	Recommended Level	Prevention / Control	Membrane Cleaning
Colloids	Silt Density Index	< 3	flocculation / UF/NF/RO	no treatment
Turbidity	NTU	< 0.5	flocculation / UF/NF/RO	no treatment
Total Suspended Solids	mg/L (ppm)	< 5 mg/L	flocculation / UF/NF/RO	no treatment
Particulates	um, absolute rating	5	filtration	no treatment
Total Hardness*	ppm	< 10	antiscalants	no CIP required
Dissolved Organics	TOC, ppm	< 1	UF	(hot) caustic / oxidation cleaning
Suspended Oil	ppm	< 5	filtration	(hot) caustic
Chlorine, free**	ppm-continuous	0.5	Sodium Bisulfite addition	no treatment
	shock treatment, ppm	100	30 minutes, 300 cycles	
	Cumulative, ppm-hrs	24000		
pH	units	0.5 - 14		-
Silica - colloidal	mg/L	< 5	antiscalants	hot caustic
Surfactants	ppm	0		
Langelier Saturation Index	Langelier Saturation Index	< 0	softening / antiscalants	Acid cleaning
Ozone	ppm	0		no treatment
Chlorine dioxide	ppm	0		no treatment
* pH shift due to degassing can contribute to precipitation				
** consider using alternative non-oxidizing biocide like DBNPA				

Table 2: Gas-side Inlet Guidelines

Gas stream (lumenside)*	0.2 µm for high-purity applications
	1 - 3 µm is sufficient for most industrial applications
*oil-free compressed dry air	

Additional Requirements

Feedwater should be free of surfactants/solvents or oxidants (e.g. ozone, chlorine) to prevent wet-out or oxidation of the hydrophobic membrane. Small amounts of chlorine and oil can be removed by activated carbon. Biological fouling can be reduced with regular, frequent chemical cleaning or sanitization procedure (see Cleaning Guide for additional information).

The physical operating limitations of Liqui-Cel® Membrane Contactors, such as maximum operating temperatures or pressures, should also be considered. For additional information refer to the *Liqui-Cel Membrane Contactor Design & Operating Guide* available at www.liqui-cel.com or contact your 3M representative.

Product Use: Many factors beyond 3M's control and uniquely within user's knowledge and control can affect the use and performance of a 3M product in a particular application. Given the variety of factors that can affect the use and performance of a 3M product, user is solely responsible for evaluating the 3M product and determining whether it is fit for a particular purpose and suitable for user's method of application.

Warranty, Limited Remedy, and Disclaimer: Unless an additional warranty is specifically stated on the applicable 3M product packaging or product literature, 3M warrants that each 3M product meets the applicable 3M product specification at the time 3M ships the product. 3M MAKES NO OTHER WARRANTIES OR CONDITIONS, EXPRESS OR IMPLIED, INCLUDING, BUT NOT LIMITED TO, ANY IMPLIED WARRANTY OR CONDITION OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE OR ANY IMPLIED WARRANTY OR CONDITION ARISING OUT OF A COURSE OF DEALING, CUSTOM OR USAGE OF TRADE. If the 3M product does not conform to this warranty, then the sole and exclusive remedy is, at 3M's option, replacement of the 3M product or refund of the purchase price.

Limitation of Liability: Except where prohibited by law, 3M will not be liable for any loss or damage arising from the 3M product, whether direct, indirect, special, incidental or consequential, regardless of the legal theory asserted, including warranty, contract, negligence or strict liability.

3M, Membrana and Liqui-Cel are trademarks of 3M Company. All other trademarks are the property of their respective owners.

© 2016 3M Company. All rights reserved. M192 Rev1



**Industrial Business Group
Membranes Business Unit**
13840 South Lakes Drive
Charlotte, North Carolina 28273
USA

Phone: +1 704 587 8888
Fax: +1 704 587 8610

**3M Deutschland GmbH
Membranes Business Unit**
Öhder Straße 28
42289 Wuppertal
Germany

Phone: +49 202 6099 - 658
Fax: +49 202 6099 - 750

**3M Japan Ltd.
Membranes Business Unit**
6-7-29, Kita-Shinagawa,
Shinagawa-ku, Tokyo | 141-8684
Japan

Phone: +81 3 6409 5732
Fax: +81 3 6409 5827



www.liqui-cel.com